



Item

Award bid for Sheep Mountain Well Tank Lining project

Responsible Staff Contact

Josh Oberlander
John Harbarger

Recommendation

Recommend awarding the Sheep Mountain Well Tank Lining project to AmTech Coatings for \$97,850.00

Executive Summary

This project will install a liner in the Sheep Mountain Well Tank, extending its useful lifespan and prevent the tank from leaking. This will keep the water tank compliant with EPA regulations.

Background

The Sheep Mountain Well Tank is a glass lined bolted steel tank installed in 1994. For several years leaks have been developing in the floor of the tank causing water to leak from the tank. This is considered a sanitary defect by the EPA and required several emergency temporary repairs to this tank. This project will consist of media blasting the inside of the tank and installing a flexible spray on liner which will be considered a permanent repair. This tank is a critical piece of infrastructure as the Sheep Mountain Well can not run without it, and this is the only tank that serves 250+ homes within the Ridgewater subdivisions.

Alignment to Strategic Doing (SD) and/or Other Plans

<u>SD24 Outcome</u>	WCC
<u>SD24 Strategy</u>	Strategy #1
<u>SD24 KPI</u>	WCC-01
<u>2014 Master Plan</u>	Maintain Solid Infrastructure

Budget/Fiscal Impact

<u>Fund/Department</u>	Public Works/Water
<u>Project/Line Item(s)</u>	31-5402-6544
<u>Budgeted Amount</u>	\$200,000
<u>Anticipated Amount</u>	\$97,850.00 Plus Engineering

Action Requested/Recommended Motion

Recommend awarding the Sheep Mountain Well Tank Lining project to AmTech Coatings for \$97,850.00 and authorize City Administrator to sign all required documentation.



CITY OF **DOUGLAS** WYOMING
HOME OF THE JACKALOPE.

Agenda Item Report City Council – 9/11/2023

Reviewed/Approved

- Community Development
- Law Enforcement
- City Administrator
- City Clerk

- Public Works
- Legal
- Finance